

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0067:227

Page 1 of 1

**CATEGORY:** Audible Signal Devices

**LISTEE:** Siemens Building Technologies/Fire Safety, 8 Fernwood Road, Florham Park, NJ 07932  
Contact: Peter Pawchak (973) 593-2662

**DESIGN:** Models U-MHU-IG, U-MHU-IG-W, U-MHU, and U-MHU-W synchronizable electronic horns and Models U-MHU-MCS and U-MHU-MCS-W synchronizable electronic horn with selectable synchronizable strobe. For synchronized operation, these devices must be used with Model SCM-F, SCM-FW or DSC, DSC-W sync control module (CSFM Listing No. 7300-0067:212), a PAD-3 notification appliance extender panel (CSFM Listing No. 7300-0067:218) or any other separately listed source of the Siemens Synchronization protocol.  
Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** 20-31 VDC  
Selectable Candela: 15cd, 30cd, 75cd or 110cd

**INSTALLATION:** In accordance with the listee's printed installation instructions, NFPA 72, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as audible and audible/visual devices for use with separately listed compatible fire alarm control units. For indoor use only.

Units can generate a distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

**XLf:** 7135-0065:172

10-08-2002KK



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **OCTOBER 8, 2002**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND**, Senior Deputy  
Program Manager